

GREENPORT FIRE DEPARTMENT

TOWN OF GREENPORT

GREENPORT PUMPER CO NO 1

BECRAFT PUMPER CO NO 2

GREENPORT PUMPER CO NO 3

GARY MAZZACANO
Chief of Department

JOHN GNUFRYCHUK JR.
1st Assistant Chief

PAUL D'ONOFRIO
2nd Assistant Chief

DATE 12/26/06

TO; GREENPORT TOWN PLANNING BOARD
Greenport Town Hall
Town Hall Drive
Hudson, N.Y. 12534

SUBJECT; SITE PLAN REVIEW THE WIDEWATERS GROUP
(Applicant / Business)
RT 9 T / GREENPORT.
(other location)

At the request of MARCO MARZOCCHI

Members of the Greenport Fire Department have reviewed the site plan and visited the actual site resulting in the following;

- 1. All Questions have been answered by applicant.
- 2. There is sufficient space available for the placement of Fire Apparatus.
- 3. There is sufficient access for Fire Apparatus
- 4. Questions remain Unanswered - see below *
- 5. Other *

** WIDEWATERS HAS AGREED TO THE 12 INCH WATER LINE WITHIN THE PROPERTY AS REQUESTED & HAS ALSO AGREED TO USE THE FIRE HYDRANTS RECOMMENDED BY THE TOWN WATER DEPT.

EXISTING FIRE CODES TO BE FOLLOWED. USE OF KNOX BOXES ADVISED

G. J. Mazzacano Fire Chief